



Building Community®

Procurement Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

October 3, 2017

ADDENDUM NUMBER: One (1)

TITLE: Main St. to Pulaski Rd – Trans – FM (CP 100-44)

JEA ITN NUMBER: 005-18

RESPONSE DUE DATE: October 31, 2017

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR
CLARIFICATIONS**

Question 1: Could we get a better description of this project?

JEA Answer 1: The Scope of work includes installation of approximately 9,600 LF of 20" PVC force main and 80 LF of 16" PVC force main, along with valves, fittings and associated appurtenances. The new force main will connect to the existing twin 10" force mains at the Main Street and Ponce Boulevard Intersection. From there, the installation route will follow Ponce Boulevard to the east, then Gillespie Avenue south to a JEA east-west utility easement. Following the easement to the east, the force main will turn south and enter the JEA owned transmission line parcel near Camden Road. Following the transmission line corridor in a southerly direction, the route will branch at Fields Road. One force main branch will run east to Pulaski Road, the other will continue south to the JEA east-west T-Line, and both branches will connect to existing force mains.

Question 2: I assume it's a Forcemain Transmission?

JEA Answer 2: Yes, it is a force main transmission line.

Question 3: Do you have an engineer's estimate?

JEA Answer 3: An engineer's estimate will not be provided.

Acknowledge receipt of this addendum on the Response Form