

245 Riverside Avenue, Suite 300
Jacksonville, Florida 32202
United States
T +1.904.733.9119
www.jacobs.com

Subject **Activity 1: Monterey WWTP Influent Pump Station Diesel Pump Capacity Evaluation**

Project Name JEA System Resiliency Program, Task Order No. 15, Monterey WWTP Assessment Services

Attention JEA

From Jacobs Engineering Group Inc. (Jacobs)¹

Date July 25, 2019

JEA Contract No. 174097

1. Purpose and Background

In September 2018, a power loss incident occurred at the Monterey Wastewater Treatment Plant (WWTP) during a storm event that resulted in a sanitary sewer overflow (SSO) of the influent manhole and wet well. JEA asked Jacobs to assess the capacity of the diesel-powered influent pump that is used during high-flow events and functions as the plant's emergency backup pump during periods of primary and backup power loss. Hydraulic modeling was conducted using a hydraulic modeling program (AFT Fathom) to assess the pump's capacity. Information used in the development of the hydraulic model included record drawings and pump curves and speed settings provided by JEA as well as site photos. This technical memorandum (TM) documents the results of the assessment and presents a discussion of the hydraulic model developed for the Monterey WWTP influent pump station.

2. Facility Description

The Monterey WWTP consists of an influent pump station, three parallel sequencing batch reactors (SBRs), an ultraviolet (UV) disinfection system, a transfer pump station, one equalization storage tank, gravity outfall, one aerobic digester (originally the fourth SBR tank), one sludge storage tank, and a centrifuge facility for sludge dewatering. The facility is permitted to discharge 3.6 million gallons per day (mgd) annual average daily flow (AADF) to the St. Johns River.

The influent pump station consists of a wetwell, mechanically cleaned bar screen, a backup manually cleaned bar screen, and an influent pump station. The influent pump station has three submersible pumps and one above grade diesel-powered pump. While the original design pump curves have been obtained for the submersible pumps and the diesel-powered pump, the design pumping capacities are not apparent from these curves, which justified the AFT Fathom model to determine the design capacity of the diesel-powered pump for this analysis. The pumps feed into a common force main that delivers influent flows to the three SBRs; one SBR unit is filled at a time. The original ductile iron force main was abandoned and replaced with a high-density polyethylene (HDPE) force main in 2018.

3. Peak Hour Influent Flow

Influent flow data are not available for the Monterey WWTP, and the effluent flowmeter is downstream of the SBRs and the equalization tank; thus, influent flow trends are difficult to determine based on the

¹ CH2M HILL Engineers, Inc. (CH2M) is now a wholly owned subsidiary of Jacobs Engineering Group Inc.

flowmeter data that are available. Per the *2018 Annual Water Resources Master Plan* (JEA, 2018), the historical AADF has been between 1.38 mgd and 2.04 mgd. The AADF has changed over time because flow transfer between Arlington East WRF and Monterey WWTP is possible and has been occurring when repairs are happening at either facility. JEA has predicted a relatively flat growth in the service area for Monterey WWTP, as the basin is mostly built-out (JEA, 2018), with the projected AADF increasing from 1.70 mgd in 2019 to 1.84 mgd in 2040. Jacobs is developing a future AADF and peak hour flow (PHF) projection that accounts for the impacts of increased sea level rise and increased rainfall due to climate change that will be submitted to JEA in a separate TM. The projected 2040 AADF increases from the JEA projection of 1.84 mgd to 2.01 mgd.

The 2040 projected PHF is 6.45 mgd (4,500 gallons per minute [gpm]). The 2019 projected PHF was calculated by applying a PHF:AADF peaking factor of 3.5 to the 2019 projected 1.70 mgd AADF (4,130 gpm). The 2040 projected PHF was then determined by increasing the flow over time and accounting for increased rainfall over time. Note that the peaking factor in 2040 is roughly 3.2 ($6.45 \text{ mgd} / 2.01 \text{ mgd} = 3.2$) because the rate of AADF increase due to climate change is more than the rate of PHF increase.

Per JEA's request, an alternate influent PHF methodology using the Ten State Standards was used. JEA provided an influent peaking factor of 2.65 which equates to a 2040 projected PHF of 3,700 gpm ($2.01 \text{ mgd} \times 2.65 = 5.3 \text{ mgd}$ or 3,700 gpm).

4. Model Assumptions, Development, and Results

4.1 Assumptions

Pipe lengths, valves, fittings, materials, and elevation data were input into the hydraulic model based on the best available information from record drawings and site photos. The water level elevations in the influent pump station and SBRs were based on information provided in the 1997 record drawings by CH2M, which were in the National Geodetic Vertical Datum of 1929 (NGVD29). Fittings losses were provided within pipe segments and not individually shown, with the exception of key junction points as shown in the model workspace included in Attachment 1 to this TM. A Hazen-Williams friction loss model was used with C-factor assumptions based on the material and age of the pipes. A C-factor of 140 was used for HDPE pipes and a C-factor of 100 was used for stainless steel and older ductile iron pipes.

4.2 Model Development and Results

The hydraulic model begins at the influent pump station and terminates at the SBRs. Attachment 1 presents a view of the model workspace. The pump curves provided by JEA for the influent pumps and entered in the model are presented in Attachment 2. The diesel pump was assumed to operate at 1,500 rotations per minute (rpm) and the submersible pumps were assumed to each have a 10.5-inch impeller diameter based on information provided by JEA. Multiple model scenarios were developed to represent different potential pump operating conditions. In each scenario, only the diesel pump was operating to assess its capacity during a period of primary and backup power loss when the submersible pumps are inoperable.

High Head Scenario: A high head scenario was developed that represents a “worst-case” scenario for the pump that will result in the lowest flow output. Under the high head scenario, the water elevation in the influent pump station was at a minimum (11.0), the water elevation in the SBR was at a maximum (45.5), and the flow was directed to the farthest SBR to maximize head loss.

Low Head Scenario: A low head scenario was developed that represents operating conditions that will result in the maximum pump output. Under the low head scenario, the water elevation in the influent pump station was at a maximum (14.0), the water elevation in the SBR was at a minimum (39.5), and the flow was directed to the closest SBR.

Average Head Scenario: An average scenario was also developed to represent typical pump operating conditions between the high head and low head scenarios.

AFT Fathom was used to develop system curves for the three model scenarios (high head, low head, average head). System curves show the total pump discharge head required for a given flow output. Figure 1 presents a plot of the system curves for the three model scenarios as well as the existing diesel pump curve at 1,500-rpm operating speed. The intersections of the pump curve and the system curves represent the predicted pump operating point for each scenario and is provided in Table 1.




Figure 1. Diesel Pump Curve vs. System Curves

Table 1. Diesel Pump Operating Conditions

Scenario	Flow (gpm)	Flow (mgd)	Head (feet)
High Head	1,255	1.8	51
Average Head	1,304	1.9	49
Low Head	1,398	2.0	45

Note: Scenarios are defined above.

The model results estimate that the diesel pump can provide approximately 1,250 to 1,400 gpm, or approximately 1.8 to 2.0 mgd, at 1,500-rpm operating speed, depending on operating conditions. Attachment 3 presents a visual view of the model workspace with select output shown for the high head scenario.

This evaluation also considered the Net Positive Suction Head (NPSH) available for each operating condition. The NPSH required was provided by the pump manufacturer. Comparison of the NPSH available to the NPSH required indicated that NPSH is a limiting factor for the pump. Increasing the pump operating speed likely would cause cavitation and potentially damage the pump.

5. Conclusions and Recommendations

Based on input from JEA, the influent pump station diesel pump is intended to provide full capacity for current and future influent PHFs during periods of primary and backup power loss when the other submersible influent pumps are inoperable. Based on JEA's provided peaking factor of 2.65, the 2019 influent PHF will be 3,130 gpm and the 2040 influent PHF will be 3,700 gpm. Attachment 4 presents a visual view of the model workspace with select output shown for the future 3,700-gpm scenario. Therefore, the modeled existing diesel pumping capacity of 1,250 to 1,400 gpm is not enough to transfer the projected current and future influent PHFs.

Because the existing influent pump station was constructed with four pump locations and three are occupied by the existing submersible pumps, there is only one location currently available for a backup diesel pump. Therefore, it is recommended to remove the existing diesel pump and replace it with a similar but larger diesel pump that meets the projected future peak hour influent flow. JEA may choose to relocate the existing diesel pump to a new location that currently does not have a backup system. The change to a larger pump will also require upsizing the current pump suction and discharge piping. Because the existing welded stainless-steel discharge piping is 12 inches, it is recommended to upsize the discharge piping and check valve to 12 inches. It should be noted that the 12-inch discharge piping will result in a short run of high flow velocity ($v=10$ feet per second), which should be accounted for in the final pump sizing.

If this recommendation is approved for implementation by JEA, it is recommended that the AFT Fathom model be validated with field measurements to verify model results prior to final pump selection. The model developed may also be used in future analyses of the Monterey WWTP influent pump station and assessments of the influent submersible pumps.

6. Preliminary Cost Estimate

A conceptual cost estimate for replacing the existing diesel pump is provided in Table 2. The total cost is approximately \$329,000. The cost estimate prepared is a facility planning level estimate and is considered a Class 5 estimate in the Association for the Advancement of Cost Engineering (AACE) International classification system. Based on AACE guidelines, Class 5 estimates range in accuracy is -20 to -50 percent on the low side and +30 to +100 percent on the high side. A 15-percent contingency was added to the sub-totaled estimated cost of each item.

Table 2. Conceptual Cost Estimate

Cost Item	Estimated Cost
Remove Existing Diesel Pump and Piping	\$2,000
Furnish and Install New 3,700-gpm Diesel Pump	\$250,000
Furnish and Install New Pump Pad	\$5,000
Furnish and Install New Diesel Pump Control Panel and Rack	\$4,000
Furnish and Install New 12" 316 SST Piping, Fittings, and Check Valve	\$25,000
Sub-Total	\$286,000
15% Contingency	\$43,000
Total Estimated Construction Cost	\$329,000

Note: Cost estimate is based on JEA O&M performing the construction work.

7. References

Crane Company. 1988. *Flow of Fluids Through Valves, Fittings, and Pipe*. Technical Paper No. 410. Joliet, Illinois.


Idelchik, I.E. 1994. *Handbook of Hydraulic Resistance, 3rd Edition*. CRC Press. Boca Raton, Florida.

Miller, D.S. 1990. *Internal Flow Systems, 2nd Edition*. Gulf Publishing Company. Houston, Texas.

JEA. 2018. *Annual Water Resource Plan*. September.

Attachment 1

Model Workspace




Attachment 2

Pump Curves

(6" x 6")

GODWIN DRI-PRIME® CD150M
ONE (1) PUMPSET DYNAMIC SUCTION LIFT
PERFORMANCE CURVES



CD150M Dri-Prime® Pump


Pump Type	CD150M
Curve No	95-1011-3098
Revision	8
Date	26 September 2014

Branch Sizes	150 x 150 mm
Speed	Variable
Max Solids Handling	3.0 " (75.0 mm)
Max Impeller Diameter	11.0 " (280.0 mm)
Min Impeller Diameter	9.4 " (240.0 mm)


godwin 
a xylem brand

CD150M


Performance



Power




NPSHr



Performance Curve – S8F/S8FX

RPM: **1750** DISCHARGE: **8"** SOLIDS: **3-1/4"**



The curves reflect maximum performance characteristics without exceeding full load (Nameplate) horsepower. All pumps have a service factor of 1.2. Operation is recommended in the bounded area with operational point within the curve limit. Performance curves are based on actual tests with clear water at 70° F. and 1280 feet site elevation.

Conditions of Service:

Attachment 3
Model Visual Report—Existing High Head
Scenario

AFT Fathom Model

Current diesel pump high head scenario


PIPE UNITS

V= feet/sec
L= feet
Dh= inches
dH= feet

JUNCTION UNITS

Qthru= gal/min
dH= feet
EL_in= feet

J1
Influent
Pump Station
Qthru=n/a
dH=n/a
EL_in=11



Attachment 4
Model Visual Report—Future Flow
Scenario

V= feet/sec
L= feet
Dh= inches
dH= feet

Qthru= gal/min
dH= feet
El in= feet

