Procurement Department Bid Office
Customer Center - 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

January 11, 2020

ADDENDUM NUMBER: Three (3)

TITLE: Purchase and Installation of Generators for JEA Lift Stations

JEA IFB NUMBER: 014-21

BID DUE DATE: ~~January 12, 2021~~**, January 20, 2021**

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 02:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. JEA is postponing the Bid Due Date for this solicitation to January 20, 2021. The question period for this solicitation is closed.

2. Question: "Will JEA supply a temporary generator or pump during the outages needed for the generator and ATS installation or is it the responsibility of the Contractor?"

   Answer: Contractor to supply any backup units required.

3. Question: "The Skinner site shows the service at 200 amps but fused disconnect shows 250 amps. Please confirm we are to keep the service at 250 amps."

   Answer: Match Disconnect at 250 AMPS.

4. Question: "May you please confirm whether we can bid as a GC if we submit using one of the JEA approved generator manufacturers listed in section 1.2.1?"

   Answer: Yes, provided you supply an approved manufacturer's generator as stated in the solicitation documents.