



Building Community®

Procurement Department Bid Office  
Customer Center – 1<sup>st</sup> Floor, Room 002  
21 W. Church Street  
Jacksonville, FL 32202

January 19, 2021

ADDENDUM NUMBER: Two (2)

TITLE: Timawatha Ave. Force Main Replacement

JEA IFB NUMBER: 018-21

PROPOSAL DUE DATE: January 26, 2021

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 02:00 PM

**JEA is responding to the following questions as shown below:**

**1. Question:**

Bid items 2 and 3 both call out to Grout Fill – 6” Force Main. Are they both 6” pipe?

**Answer:**

No, the description for Bid Item No. 3 should read “Abandon Pipe – Grout Fill 8” Gravity Sewer”.

**2. Question:**

There is no line item for Testing Allowance, will payment for this item be handle through SWA?

**Answer:**

No, the cost for testing shall be included within the unit price for the work task incidental to the testing.

**3. Question:**

There is no line item for Officer Allowance, does JEA expect not to use officers for this project?

**Answer:**

No, JEA does not anticipate the use of officers for the proposed work.