



Building Community®

Procurement Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

November 27, 2017

ADDENDUM NUMBER: ONE (1)

TITLE: BRANDY BRANCH GENERATING STATION COMBUSTION TURBINE (CT) B51 EXHAUST DUCT
SILENCER REPLACEMENT PROJECT

JEA ITN NUMBER: 023-18

RESPONSE DUE DATE: DECEMBER 19, 2017

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR
CLARIFICATIONS**

CHANGE: The minimum qualification form issued with addendum 1 replaces the minimum qualification form issued with the original solicitation. The reference to “Number of Networked Devices” has been deleted.

CHANGE: The Bid Form issued with Addendum 1 replaces the Bid Form issued with the original solicitation. Public records certification has been added to the form in red underlined font.

CLARIFICATION: The Bidder (also referred to as the “Prime Contractor”) is required to have a valid State of Florida General Contractors (GC) License, or alternately, the Prime Contractor may utilize a Subcontractor with a State of Florida GCLicense for installation. The Prime Contractor shall provide the Subcontractor GC license number with the Bid. The Prime Contractor will be responsible to maintain a Payment and Performance Bond in the amount of the bid amount, and both the Prime Contract and Subcontractor shall carry all applicable insurances required by this Solicitation.

SUPPLIER INQUIRY: Is there a sound study requirement by the contractor as a part of this scope of work? If JEA will perform an independent sound study, can JEA provide the type of study to be performed.

JEA RESPONSE: Contractor to provide sound attenuation testing to determine decibel readings are at or below specified values. JEA shall witness testing before final acceptance of installation and final payment.

SUPPLIER INQUIRY: Who is responsible for Equipment Offload at the Brandy Branch Generating Site, JEA or the Company?

JEA RESPONSE: The Company is response for the Offloading and handling of all equipment associated with the Work. Contract shall be turn-key. Contractor responsible for any electrical, mechanical, structural, etc. work required.

ADD: See attached photos for delineation of extent for replacement of duct/silencer.

Acknowledge receipt of this addendum on the Response Form