



Building Community®

Procurement Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

3/05/2020

Addendum Number: **Four (4)**

Title: **Kennedy Generating Station Fire Protection Loop Replacement**

JEA Solicitation Number: **028-20**

Response Due Date: **March 17, 2020**

Due Date Time: **12:00 PM**

Time of Opening: **2:00 PM**

This addendum is for the purpose of making the following additions, deletions and changes.

Change: The Bid Due Date has been changed to March 17, 2020. A final Addendum will be issued answer final questions.

The following Additional specifications are added to this Addendum 4 and replace the specification issued in Addendum 3.

- 028-20 Appendix A Carbozinc 859-ProductFlyer-1014 (1)
- 028-20 Appendix A ZRC – touch up coating.pdf
- 028-20 Appendix A Carbozinc_859_PDS (1)

In Addendum 3, the two following inquiries were responded to. After additional review, JEA has received revised responses from the Engineering of Record for this project. The following two responses replace the responses provided by JEA in Addendum 3.

Supplier Inquiry: What is the method of priming and coating the pipe?

JEA Response: There won't be any priming or coating of pipe, it will be galvanized per the 11CE2F.

Supplier Inquiry: What is the method of galvanizing the field welds?

JEA Response: Use the ZRC touch up specification attached to this Addendum 4.

Acknowledge receipt of this addendum on the Response Form