



Building Community®

Procurement Bid Office  
Customer Center 1<sup>st</sup> Floor, Room 002  
21 W. Church Street  
Jacksonville, Florida 32202

December 29, 2017

ADDENDUM NUMBER: **039-18**

---

TITLE: **PURCHASE AND INSTALLATION OF PONY PUMPS FOR JEA LIFT STATIONS**

---

JEA ITN NUMBER: **039-18**

---

RESPONSE DUE DATE: **01/23/2018**

---

TIME OF RECEIPT: **12:00 PM**

---

TIME OF OPENING: **2:00 PM**

---

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

**CHANGE:** The Bid Due Date has been changed to January 23, 2018.

**ADD:** An additional prebid meeting will be held on January 3, 2018, 10:00 a.m. in the JEA Customer Center, 1<sup>st</sup> Floor, Room 002, Bid Office, 21 West Church street, Jacksonville, FL 32202. Bidders that attended the first prebid do not need to attend the second prebid. All Bidders shall have attended one prebid to have their bid opened at bid opening.

Teleconference: 1-888-714-6484

Participation code: 992663

**CHANGE:** JEA has resized the posted the drawing and layouts to JEA.com.

**ADD:** New Pump Spec Addednum.

**SUPPLIER INQUIRY:** Who is responsible for fueling the diesel tanks?

**JEA RESPONSE:** Bidder will be required to fill tanks.

**SUPPLIER INQUIRY:** Can the pump stations be shut down or will we be required to bypass pump?

**JEA RESPONSE:** When a pump out connection is not available the pump station will need to be shut down and bypass pumping will be the responsibility of the bidder. General note to that effect is on the drawings, will ensure it is on all drawings when addendum is added. Run times for stations are available to assist in planning bypass pumping requirements.

**SUPPLIER INQUIRY:** Must all pumps be by the same manufacturer?

**JEA RESPONSE:** No

**SUPPLIER INQUIRY:** Are the liquidated damage aggregate capped at 15% or 10%? See Solicitation 2.5.1.

**JEA RESPONSE:** Liquidated damages are capped at 10%.

**SUPPLIER INQUIRY:** In accordance with Florida State Statute "Public Bid Disclosure Act" Section 218.80, we need to know the dollar amount of all permits and fees required specific for this project.

**JEA RESPONSE:** JEA does not have a list of permits or fees required for this project.

**Acknowledge receipt of this addendum on the Response Form**