

Lenny Curry, Mayor

Planning and Development/ Development Services 214 N. Hogan St. Jacksonville, FL 32202 (904) 255-8310 www.coj.net

October 5, 2020

Jones Edmonds 8657 Baypine Road, Suite 300 Jacksonville, FL 32256-8634 (904) 744-5401

Attn: Kenneth A. Fraser, P.E.

RE: Beverly Hills West Septic Tank Phase-out

Utility Construction Plan Review City Development Number: 4161.308

Mr. Fraser.

The above referenced plans were approved as noted July 1, 2020 and are available in the City of Jacksonville's e-plan review system: JaxCivilPlan.coj.net.

All correspondence with this office must include the City Development Number and addressed to Development Services, 214 N. Hogan St., Room 2100 Jacksonville, FL 32202; ATTENTION: Ellyn Cavin.

## **MOT Review Approved As Noted Comments:**

- •All road closures shall be coordinated with COJ Traffic Engineering Division.
- •Stop bars/lines shall be placed adjacent to the existing stop signs as directed by Traffic Engineering Division Striping Coordinator. All final pavement marking after asphalt curing shall be extruded thermoplastic.
- •Update the Utility Contacts Phone number for Traffic Engineering. It is 255-7533. Please check on and update any other numbers in the Utility Contact List.

Sincerely,

Kevin Robinson, Engineering Tech. Principal Development Services Review Group review.jaxdev.com