



Procurement Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

June 15, 2018

ADDENDUM NUMBER: Two (2)

TITLE: Supply of Northside Substation T6 with one Autotransformer

JEA SOLICITATION NUMBER: 103-18

RESPONSE DUE DATE: June 26, 2018

DUE DATE TIME: 12:00 PM

TIME OF OPENING: 2:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING ADDITIONS, DELECTIONS, CHANGES OR CLARIFICATIONS

CHANGE: The Bid Due Date has been changed to June 26, 2018, 12:00 PM Noon (EST).

Supplier Inquiry: We need clarification regarding the Tap Changers on the specified transformer. 17.2 Requires LTC to be connected to and regulate the LV winding. Our expectation would be that for a transformer with these ratings the LTC would be connected to and regulate the HV winding.

- **JEA Response - The LTC for this unit should regulate the HV winding, not the LV winding.**

Supplier Inquiry: We need clarification regarding the Tap Changers on the specified transformer. Also, 17.15 requires a Reinhausen RMV II. Would other Reinhausen LTC's be acceptable?

- **JEA Response - Other Reinhausen LTC's would be acceptable.**

Acknowledge receipt of this addendum on the Response, Bid or Proposal Form