



Building Community®

Procurement Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

August 1, 2017

ADDENDUM NUMBER: ONE (1)

TITLE: General Construction Services for Greenland Energy Center Fuel Oil and Demineralized Water Storage Tank Additions

JEA ITN NUMBER: 125-17

RESPONSE DUE DATE: August 29, 2017

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR
CLARIFICATIONS**

The following Additional document and drawings have been added to this Addendum 1:

- 125-17 Addendum 1 - Appendix A Drawings
- 125-17 Addendum 1 - Appendix A E 7.605.2 Particle Measurement Technology in Practice
- 125-17 Addendum 1 - Appendix A GEK 110483C Cleanliness Requirements
- 125-17 Addendum 1 - Appendix A JEA GEC Geotechnical Report
- 125-17 Addendum 1 - Appendix A M013784.572E023. Fire Alarm Interface Panel IP4

SUPPLIER INQUIRY: The plans do not include existing grades. Please advise what existing topography to base the proposed grades.

JEA RESPONSE: The existing contours and spot elevations are shown in the background on CSTF-S3030 in screened (lighter) line weights per the legend. The existing spot elevations are also show with x marks, while new spot elevations are shown with + marks.

Acknowledge receipt of this addendum on the Response Form