



Procurement Bid Office
21 W. Church Street
Jacksonville, Florida 32202

August 3, 2022

ADDENDUM NUMBER: One (1)

TITLE: Mandarin Water Reclamation Facility (WRF) Sludge Holding Tanks Rehabilitation

JEA IFB NUMBER: 1410805246

BID DUE DATE: ~~August 30, 2022~~ September 7, 2022

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

Change: The Bid Due Date has been extended to September 7, 2022

Add: An optional site visit has been added:
Wednesday, August 10, 2022 at 11:00 a.m.
Mandarin WRF
10828 Hampton Road
Jacksonville, FL 32257
Email Zasha Del Orbe rivezd@jea.com to get on the Security list for access.

Question 1: When will Aquastore have the temporary glass line tank in place?

A: It is anticipated that Aquastore will have the tanks substantially in place by February 2023 with final completion in March 2023.

Question 2: Who is responsible for demolition the temporary tanks?

A: Demolition of the temporary tanks is part of the scope of work for this Solicitation.

Question 3: What is the thickness of the existing linings and what type are they?

A: JEA has the original design drawings, but does not have the technical specifications of what was installed. At the site visit, potential bidders can see inside the tanks, but they are in operation, so visibility is limited.

Question 4: Are linings being removed from both tanks?

A: The thickened sludge tank shows damage and will need to be replaced. In the waste sludge holding tank no damage has been visualized, only needs to be cleaned and inspected. Any repairs/replacement will be an additional scope of work.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.