



Headquarters - Procurement Department
225 North Pearl Street
Jacksonville, Florida 32202

January 2, 2024

ADDENDUM NUMBER: One (1)

TITLE: Construction Services for Monterey Wastewater Treatment Facility (WWTF) Improvements.

JEA SOLICITATION NUMBER: 1411527446

BID DUE DATE: January 30, 2024; January 9, 2024

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 02:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Attachment:** 1411527446 Addendum 1 Appendix B – Bid Workbook
2. **Change:** The Bid Due Date has been extended to January 30, 2024, at 12:00 noon.
3. **Change:** The Solicitation title is changing to: Construction Services for Monterey **Wastewater Treatment Facility (WWTF) Improvements**
4. **Correction:** The site visit location is 5802 Harris **Avenue** (not Street), Jacksonville, FL 32211
5. **Question: REF:** Appendix B-Bid Workbook, Item 40 – Type E concrete repairs are for cracks. Should the unit of measure be LF in lieu of SF?
Answer: JEA Standard 448 - V.5 - The cracked areas shall be repaired in accordance with the Contract Documents. The Unit of Measure shall be Linear Foot (LF). Workbook Item 40 corrected (see attached).
6. **Question: REF:** Dwg LA-05 – What specification shall be used for Landscaping? If the JEA Standard is to be followed, which standard?
Answer: Page LA-06 indicates the Specifications for Landscaping. Reference JEA Water and Wastewater Standards Section XV – Landscaping and Irrigation System Standards.
7. **Question: REF:** Dwg E-06 – This drawing shows a 2000KW/2500KVA Generator. However, Bid Item 20 indicates 600KW. Please clarify which to include in the bid.
Answer: Item 20 of the Bid-Workbook corrected (find attached). The project will require a 2000kW/2500kVA as indicated in Page E-06.

8. **Question:** Specification section 11330, paragraph 2.02.D.2, requires the screen manufacturer to provide motor operated stainless-steel ball valves. Please confirm which actuator model shall be provided.

Answer: The Screen Manufacturer shall provide the ball valve actuators with the rest of their scoped equipment and shall include the actuator model within the shop drawing provided to the contractor.