



Procurement Department Bid Section
225 North Pearl Street
Jacksonville, Florida 32202

February 13, 2024

ADDENDUM NUMBER: Two (2)

TITLE: IFB Westside Service Center Glove Lab and Administration Building - 1411562446

RESPONSE DUE DATE: February 27, 2024

TIME OF RECEIPT: 12:00 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Question:** Please confirm all the rooms that will have the epoxy system.

Answer: The rooms in the laboratory areas will have the epoxy system.

2. **Question:** I also want to submit an equal substitute for the epoxy system from sheet A-101/ Material Finish Schedule. Material finish schedule has SW Resuflor Deco Quartz (FL-1). The DecoDur Quartz FX is equal.

Answer: JEA intends to use the JEA Standards approved Sherwin-Williams Resuflor Deco Quartz BC23 1/8" system.

3. **Question:** I'm emailing you today in regard to the above-mentioned project with the hope of submitting a product substitution request on behalf of our Viper II under-slab vapor barriers. Request the addition of VIPER® VAPORCHECK® II to your firm's master specification (033000 or 072600).

Answer: The Viper Vaporcheck II is acceptable as an equal product to the Stego Wrap (15 mil) product specified.

4. **Link provided for Appendix A – Drawings – Bid Set:** Use link below to access full set of drawings that will be available until 2/19/24.

<https://pqh.sharefile.com/public/share/web-s4602fcdffcac401bbb18315fa4252a86>

5. **Change to Appendix A – Drawings – Bid Set - MECHANICAL:**

1. General note added to M500, M501, and M502:
"ALL CONTROLS SHALL BE STRUXUREWARE"

6. **Change to Appendix A – Drawings – Bid Set - PLUMBING:**

1. Sheet P600 Change the Specification for DF-1 in plumbing fixture schedule from LZS8WSLK to LZSTL8WSLP.

7. **Change to Appendix A – Project Manual - SPECIFICATION:**

1. Add Section 113100 APPLIANCES attached.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE RESPONSE FORM