



Procurement Department Bid Section

October 15, 2024

ADDENDUM NUMBER: THREE (3)

TITLE: 1411836846 (RFP) N01 Isolated Phase Bus System Overhaul

PROPOSAL DUE DATE: ~~October 08, 2024~~, ~~October 15, 2024~~, October 22, 2024

TIME OF RECEIPT: 12:00 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Change:** The bid due date has been extended to 10/22/2024.
2. **Question:** For the ground bar not being removed, do you want it to be plated on site? And does this require the ISO9001 certification?

Answer: Yes, the ground bar that is not able to be removed will be plated on site and **does not** require an ISO9001.

An ISO9001 (or JEA approved equivalent certification relevant to the metal electroplating industry) is required for the offsite electroplating.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.