

BID EVALUATION MATRIX - COMPLIANCE AND PRICING

Evaluation Matrix	Data			Ratings			Rating Criteria Definitions		Evaluator Notes		
	Bidder 1	Bidder 2	Bidder 3	Bidder 1	Bidder 2	Bidder 3	Compliant	Non-compliant	Bidder 1	Bidder 2	Bidder 3
Key Compliance/Non-Compliance Criteria:				Compliant/Non-Compliant							
Key Commercial Terms (Reference "Key Commercial Terms" Tab)							Bidder proposed terms do not contain any major deviations from IEA requested commercial terms.	Bidder proposed terms contain major deviations from IEA requested commercial terms.			
Specification Compliance							Bidder complies with requirements as detailed in the Request for Proposal (RFP).	Bidder does not comply with requirements as detailed in the Request for Proposal.			
Project Delivery Schedule							Bidder can meet the equipment delivery schedule in the RFP or Project can accept the Bidder's proposed delivery schedule.	Bidder is unable to meet the equipment delivery schedule in the RFP and the Bidder's proposed delivery schedule is not acceptable for the Project schedule.			
Minimum Performance Levels							Bidder meets the Minimum Performance Levels of the RFP.	Bidder does not meet the Minimum Performance Levels of the RFP.			
Liquidated Damages							Bidder proposes Liquidated Damages amounts requested in the RFP.	Bidder proposes lower Liquidated Damages amounts than requested in the RFP.			
Emissions Guarantees							Bidder meets all Emissions Guarantees specified in the RFP.	Bidder does not meet all Emissions Guarantees specified in the RFP.			
Noise Guarantees							Bidder meets all noise guarantees specified in the RFP.	Bidder does not meet all noise guarantees specified in the RFP.			
Equipment Operating Experience							Offered equipment has a minimum of 8,000 hours of commercial operation at each of a minimum of 3 different sites expected prior to planned project 2030 COD.	Offered equipment does not have 8,000 hours of commercial operation at each of a minimum of 3 different sites expected prior to planned project 2030 COD.			
Equipment Operation on Fuel Oil							Offered equipment has proven commercial operation on fuel oil.	Offered equipment does not have proven commercial operation on fuel oil.			
Baseload Net Electrical Output meets minimum requirement of 525 MW							Bidder supplied net (plant) electrical output above 525 MW.	Bidder did not supply a net (plant) electrical output above 525 MW.			
LTSA Offer							Bidder provides commercially acceptable LTSA Offer.	Bidder does not provide commercially acceptable LTSA Offer.			
Bidder has had No Major Failures, or has Adequately Addressed Major Failures for any Operating Units							No major failures have occurred, or any major failures have been adequately addressed.	Major failure has occurred and has not been adequately addressed.			
Project Submittal Schedule							Bidder is able to meet the document submittal requirements proposed in the RFP in order for engineering to proceed.	Bidder is unable to meet the document submittal schedule in the RFP.			
Final Rating:				Non-Compliant	Non-Compliant	Non-Compliant					
Key Evaluation Criteria							Key Evaluation Description				
Power Island Equipment Price (Firm Lump Sum): - Price - Transportation (DDP Jobsite) - Startup and Commissioning Spare Parts - On-Site Technical Advisory (TA) Services - Security Instruments - Operation and Maintenance Manual							Bidder to quote a cost for all the items listed. TA Services: As detailed in 67 9100 Technical Specification for Power Island Equipment.				
Power Island Equipment Supplier Price Adjustments							After E&Cs have been finalized				
Adjusted Contract Cost \$ - \$ - \$ -											
Evaluation Factor: Milestone Payments for Owner's Costs							Cash outlay up front				
Evaluation Factor: Construction cost differential							Guaranteed quantities, other factors which would affect the overall construction cost				
Evaluation Factor: Balance of Plant cost differential							Cost differential for overall Balance of Plant construction				
Total Evaluated Price (Sum of Rows 24-27) \$ - \$ - \$ -											