



Procurement Department Bid Section
225 North Pearl Street
Jacksonville, Florida 32202

February 6, 2025

ADDENDUM NUMBER: Six (6)

TITLE: IFB District II (Cedar Bay) WRF New Plant Entrance Construction - 1411900647

RESPONSE DUE DATE: ~~January 21, 2025~~ **February 11, 2025**

TIME OF RECEIPT: 12:00 PM ET

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Question:** RE Addendum #05. Where is building #9? Is it within the 750 feet shown on note 13?

Answer: Building #9 is marked as MCC1 on 1411900647 Addendum 4 - Electrical Plans – Revised 2025-01-16 sheet E2.2. The conduits are as shown connect Building #9 (MCC1) to the new gate panel, no connection to be made to the existing main gate security panel. Note #13 is no longer applicable.

2. **Question:** How much pipe inside of building (#9) will be needed?

Answer: No pipe is needed inside the building; the conduit will extend up to the building. JEA security and telecommunication's contractors are responsible for the connections within the building, our construction is limited to providing the conduits only.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID FORM