



NOTES:

1. CONCRETE STRENGTH - 3,000 P.S.I. MINIMUM
2. REINFORCING STEEL - NO. 5, GRADE 60
3. LIFTING INSERT - DAYTON SUPERIOR NO. F-53  
OR APPROVED EQUAL

		DISTRIBUTION MATERIAL DETAIL PRECAST THREE PHASE TRANSFORMER PAD			ITEM ID	PADCD007
REVISED BY: SGL		<b>JEA</b>			DMD NO.	DMD-78
DATE: REV. 1/8/92	REVIEWED BY:				SHEET NO.	1 OF 1
		DATE:	APPROVED BY:	DATE:		