



Procurement Department Bid Section

June 11, 2025

ADDENDUM NUMBER: FIVE (5)

TITLE: 1411975246 (IFB) Brandy Branch Generating Station Turbine Parts Warehouse

PROPOSAL DUE DATE: ~~June 10, 2025~~ June 17, 2025

TIME OF RECEIPT: 12:00 PM EST

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR
CLARIFICATIONS:**

1. **Question:** Does the wall panels for the building have to be an insulated wall panel? OR Is it regular metal wall panel with insulation backing?

Answer: Either insulated panels, or insulation behind the siding is acceptable provided we meet the R-values set forth in the specs.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.