



Procurement Department Bid Section

May 19, 2025

ADDENDUM NUMBER: TWO (2)

TITLE: 1411979046 (IFB) St Johns 4kV Substation Rebuild

PROPOSAL DUE DATE: May 28, 2025

TIME OF RECEIPT: 12:00 PM EST

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

1. **Question:** Does the JEA know how thick the existing Transformer Pads are?

**Answer:** The foundations of the existing Transformers are believed to be up to 18 inches thick. Please see attached drawings, cross section "A-A". JEA makes no guarantees with regards to the accuracy of these drawings, as there may be discrepancies. The drawings are being provided as-is.

2. **Question:** I need confirm If Site Plan, Demolition, Grading, Paving, Drainage, etc., is included in this scope.

**Answer:** Yes. The contractor is responsible for the entire scope as identified in the tech. specs and drawings.

3. **Question:** What is the weight of the existing Transformer to be removed?

**Answer:** To be answered in an upcoming addendum.

4. **Question:** What are the weights of the New Transformers that are to be Hauled from Hamilton Sub to the St. Johns site?

**Answer:** To be answered in an upcoming addendum.

5. **Question:** What is the weight of the Switch Gear to be placed on the new pad?

**Answer:** To be answered in an upcoming addendum.

6. **Addition:** JEA adds "1411979046 Addendum 2 Appendix C - Additional Drawings"

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.**