



Procurement Department Bid Office
225 N. Pearl Street
Jacksonville, FL 32202

September 22, 2025

ADDENDUM NUMBER: Six (6)

TITLE: Mandarin WRF - Switchgear Control Upgrade

JEA IFB NUMBER: 1411989846

PROPOSAL DUE DATE: ~~September 23, 2025~~ September 30, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 02:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

JEA is extending the bid due date to September 30, 2025

JEA is providing the following Forms:

1411989846 Addendum 6 Appendix B - Bid Workbook

JEA is responding to the following questions as shown below:

1. Question:

REF: Appendix A. Drawings, E01.3 TRYSTAR 1200A SINGLE BREAKER DOCKING STATION SBDS-XXX.
Are there any additional specifications for this item?

Answer:

TRYSTAR 1200A SINGLE BREAKER DOCKING STATION SBDS-125W-LF-I

2. Question:

Are they expecting Russ to include in the quote a Network Rack with the SEL-RTAC & SEL-2488? Can it be a freestanding cubicle with the SEL's mounted as door devices along with the Remote OIP?

Answer:

Yes, the network rack should include the SEL-RTAC and SEL-2488. The preference is that it be a wall mounted rack per the following link

https://www.lowellmfg.com/product-category/racks-cabinets-in-wall-boxes/?ixwpst%5Bproduct_cat%5D%5B%5D=9632&ixwpst%5Bpa_rack-style%5D%5B%5D=11963&ixwpsf%5Btaxonomy%5D%5Bproduct_cat%5D%5Bshow%5D=set&ixwpsf%5Btaxonomy%5D%5Bproduct_cat%5D%5Bmultiple%5D=1&ixwpsf%5Btaxonomy%5D%5Bproduct_cat%5D%5Bfilter%5D=1&ixwpsf%5Btaxonomy%5D%5Bpa_rack-style%5D%5Bshow%5D=set&ixwpsf%5Btaxonomy%5D%5Bpa_rack-style%5D%5Bmultiple%5D=1&ixwpsf%5Btaxonomy%5D%5Bpa_rack-style%5D%5Bfilter%5D=1
RACKS | Lowell Manufacturing Company

Acknowledge receipt of this Addendum on the Proposal Form (Appendix B)

3. Question:

Please confirm the circuit breaker serial numbers

Answer:

The complete table is listed here

	Breaker Catalog Number	Breaker Serial Number	Breaker Frame Size	Sensor
C1	AKR-10F-75	0357A3376-006-002	3200	3200
C2	AKR-10F-76	0357A3376-016-002	3200	3200
UM1	AKR-10F-77	0357A3376-001-004	3200	3200
UM2	AKR-10F-78	0357A3376-006-001	3200	3200
GM1	AKR-10F-79	0357A3376-001-001	3200	3200
GM2	AKR-10F-80	0357A3376-001-003	3200	3200

Acknowledge receipt of this Addendum on the Proposal Form (Appendix B)