



Headquarters - Procurement Department
225 North Pearl Street
Jacksonville, Florida 32202

August 5, 2025

ADDENDUM NUMBER: One (1)

TITLE: RFP General Substation Construction

JEA SOLICITATION NUMBER: 1412012050

BID DUE DATE: August 19, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 02:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Question:** Are all the equipment units to be "By the hour" like the labor units?

Answer: Yes, equipment units are per hour unless stated otherwise.

2. **Question:** Are there further dimensions for the concrete slab foundations? The only provided dimensions are 18" or 24". I know these slabs can vary in width and length per situation at times and wanted to ensure the bid was appropriate. Can the widths and lengths of the slabs be provided?

Answer: The provided value is for the depth of the foundation. Unfortunately, the size of the foundation will be job dependent, and the foundation width and length will vary per job, therefore we ask that you bid per cubic foot.

3. **Question:** Does the # symbol “#” represent PSI?

Answer: Yes, the # symbol does represent PSI.

4. **Question:** Are these values to include the form work, form materials, rebar and manpower to be included as required for installation of these foundations?

Answer: This figure should include all the necessary work, material, rebar, test, etc, to provide a finished foundation. See the definitions page in the Appendix A – Technical Specifications for details.