



Procurement Department Bid Office  
225 N. Pearl Street  
Jacksonville, FL 32202

August 28, 2025

ADDENDUM NUMBER: Two (2)

TITLE: Construction Services for Royal Lakes Water Treatment Plant

SOLICITATION NUMBER: 1412016650

PROPOSAL DUE DATE: September 9, 2025 September 23, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 02:00 PM

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

**JEA is extending the Bid Due Date for this Solicitation.**

**Original Due Date:** September 9, 2025

**Updated Due Date:** September 23, 2025

**JEA is answering questions received in reference to this Solicitation.**

1. **Question:** Can JEA provide color details for split face CMU?

**Answer:** The selected contractor must submit the color chart and samples for color selection by JEA.

2. **Question:** Can JEA provide preferred manufacturers for ground storage tank ventilation fans?

**Answer:** For the new Ground Storage Tank, Ventilation Fans must comply with section 434163. Please refer to Sections 434163 (2.1-B3) and 434163 (2.2-J) of the Technical Specifications.

3. **Question:** We request a bid extension to September 23rd as multiple subcontractors have requested an extension due to the holiday and desire to submit more complete proposals.

**Answer:** Due date has been extended to September 23<sup>rd</sup>.

**JEA is making changes to the Technical Specifications related to this Solicitation.**

1. **Prestressed Ground Storage Tank Interior Coatings**

- a. Section 434163 Part 2.2.M.2.b: Replace first sentence with "Underside of dome and top three (3) feet of interior walls."