



Procurement Department Bid Section

August 27, 2025

ADDENDUM NUMBER: TWO (2)

TITLE: 1412020648 (IFB) Brandy Branch Generating Station B52-B53 SCR Catalyst Replacement

PROPOSAL DUE DATE: September 3, 2025

TIME OF RECEIPT: 12:00 PM EST

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

1. **Question:** Does the Brandy Branch site have a resident or usual scaffolding company?

**Answer:** JEA has a contract with Sunbelt for scaffolding services at our plant sites.

2. **Question:** The specifications indicate inlet CO from 3-8 ppmvdc with an outlet stack limit of 14 ppmvdc. Why are they asking for a DF catalyst option? What is the required CO oxidation rate? What catalyst life guarantee are they requiring?

**Answer:** Future considerations include a CT AFS upgrade which would reduce the MECL for the unit. DF catalyst is expected to provide a bit of additional CO margin when operating at min load. At the bottom of Appendix A, Catalyst Bid Form "> 75 CO conversion". Our current catalyst has lasted 20+ years. A catalyst life of 7 to 15 years is expected, and the Catalyst Life Guarantee will be one of the quality parameters used for making the bid selection recommendation.

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.**