



Procurement Department Bid Office
225 N. Pearl Street
Jacksonville, FL 32202

11/26/2025

ADDENDUM NUMBER: Three (3)

TITLE: RiverTown Storage Tank and Pumping System – Phase I

JEA IFB NUMBER: 1412058249

PROPOSAL DUE DATE: ~~December 2, 2025~~, December 09, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

Update: JEA is extending the bid due date for this Solicitation to **December 09, 2025**.

Change: JEA is providing the following changes to the Specifications.

Replace Appendix D in its entirety with the attached revised Appendix D. Embedment language has been revised per Addendum 2 (Question No. 7) and the geotechnical report has been re-signed due to these updates.

1412058249 Addendum 3 Appendix D – Geotechnical Report

JEA is responding to the following questions as shown below:

1. **Question:** Please confirm if we are to include the lightning protection on the tanks? Or will this be by the Phase II contractor?

Answer: Lightning protection is to be installed by the Phase II contractor. Drawing E-12 was included as reference only so that the Phase I contractor can provide bossing on the tank for the electrical components that will be installed by the Phase II contractor.

2. **Question:** Are we to include the Tree Fund Payment (\$56,175.00) detailed on sheet L-3 in our contract amount?

Answer: No, this is already paid by JEA.