



Procurement Department Bid Section

January 27, 2026

ADDENDUM NUMBER: ONE (1)

TITLE: 1412104046 (IFB) Acid & Caustic Pipe Replacement

PROPOSAL DUE DATE: February 24, 2026

TIME OF RECEIPT: 12:00 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. Clarification: The mandatory pre-response meeting/site visit is on February 4, 2026 at 10AM EST. See details below:

**Location: 4433 William Ostner Road, Jacksonville FL 32226
(EPPM 10-Wide Conference Room)**

- Attendees to provide representing company name and full names of attendees to be added to the security visitor list at least 24-hours prior to arrival. Please bring government issued photo ID.
 - All visitors will be escorted in from the Contractor Gate located on William Ostner Blvd. Please arrive by 09:45AM.
- Pre-Bid Meeting will begin at 10AM within the EPPM 10-Wide Conference Room. A site walk of the project will immediately follow the meeting.
 - Visitors should come equipped with hard hat, safety shoes/boots, and safety glasses. These will be required for the site walk.
 - Photos of the project area are acceptable during the site walk.
 - All attendees shall be always escorted by JEA personnel while at NGS.

Those planning to attend the Mandatory Pre-Bid/Site Visit should send contact information to: Hans Connell, connhe@jea.com and Jason Behr, behrjv@jea.com

2. JEA adds “1412104046 Addendum 1 - Appendix A - Revised Technical Specifications” document to this solicitation. Revisions are noted below:

- Section 2.0 Scope of Work:
 - The sulfuric acid piping will be replaced with of **1 ½" Schedule 40** - 316 Stainless Steel Teflon lined pipe, all fittings and valves are flanged with socket weld connections, 150 lb/B16.5, 316 Stainless Steel.
- Sodium Hydroxide:
 - 1" Carbon Steel with Heat Tracing Schedule 80
 - All fittings and valves are flanged with **socket weld connections**, 150 lb/B16.3 malleable iron.
 - 27 manual globe valves
 - 4 check valves

- Section 3.2 Schedule:
 - A pre-bid meeting and mandatory site-walk will be held 10:00 A.M. at NGS on February 04, 2026. Please RSVP at least 24 hours in advance with Hans Connell, 386-983-6313, connhe@jea.com.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.