



Procurement Department Bid Section

February 18, 2026

ADDENDUM NUMBER: ONE (1)

TITLE: 1412104246 (IFB) B52 B53 Leaf Seal Replacement

PROPOSAL DUE DATE: February 24, 2026

TIME OF RECEIPT: 12:00 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Question:** Could you confirm the Inside Flow diameter at the A042 Diffuser duct outlet connection?

Answer: The inside flow diameter is 192”.

2. **Question:** When are the proposed outage dates?

Answer: Working dates are 3/24/26 – 4/2/26

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.