




5/9/2002

UTILITY ENGINEERING

- DAM



FYI

"N" NUMBER OF HOLES	164
DESIGN TEMPERATURE	1300°
DESIGN PRESSURE	26" WG
"T" INSULATION THKN'S 8# DENSITY CERAMIC	5"
"C" BELT I.D.	17'-3 1/4"

A	05-APR	INITIAL RELEASE	KLB	ELK	
REV	DATE	REVISION	BY	CHK	

NENOOTER/ERIKSEN

DWN	KLB	INLET EXPANSION JOINT					
CHK	ELK						
PM		OWNER: JACKSONVILLE ELECTRIC AUTHORITY (JEA)					
PE	JLK	PURCHASER: BE&K / UTILITY ENGINEERING					
SE		PROJECT: BRANDY BRANCH					
TE		PLANT SITE: BALDWIN, FL					
PROJECT:		RELEASE DATE: 05-APR-2002					
JEA BRANDY		JOB	NO	CODE	SHT	REV	FE
DRAWING NUMBER		014143-EJ-N-03				A	