



5/23/2002

M010322-201A007 RA
JEA BRANDY BRANCH

Review does not relieve contractor from responsibility for errors or deviations from contract requirements

NO EXCEPTIONS NOTED
Release for manufacture

EXCEPTIONS NOTED
Release for manufacture
Revise and resubmit for distribution

RETURNED FOR CORRECTION
Do not proceed
Revise and resubmit for authorization

UTILITY
ENGINEERING

CHART FOR ALL DETAILS

"A" DIM. FROM TANGENT (HORIZONTAL)	5/8"
"B" NO. OF HOLES (HORIZONTAL)	61
"C" VERTICAL INSIDE DIM. OF BELT	20'-9 1/4"
"D" DIM. FROM TANGENT (VERTICAL)	5/8"
"E" NO. OF HOLES (VERTICAL)	61
"F" HORIZONTAL INSIDE DIM. OF BELT	20'-9 1/4"
DESIGN TEMPERATURE	1300°
DESIGN PRESSURE	26 WG
"T" INSULATION THKN'S B# DENSITY CERAMIC	5"

OWN	JJB	INLET EXPANSION JOINT DESIGN DRAWING
CHK	JDF	
PE	JLK	
SE		
TE		

OWNER: JACKSONVILLE ELECTRIC AUTHORITY (JEA)
PURCHASER: BE&K / UTILITY ENGINEERING
PROJECT: BRANDY BRANCH
PLANT SITE: BALDWIN, FL

RELEASE DATE: 03-MAY-2002

PROJECT:	JEA BRANDY	JOB NO	CODE	SHT	REV	FE
DRAWING NUMBER	014143-EJ-N-04					