



ROOF LINER VIEW

Review does not relieve contractor from responsibility for errors or deviations from contract requirements

UTILITY ENGINEERING

MRW

- ☒ NO EXCEPTIONS NOTED
Release for manufacture
- ☐ EXCEPTIONS NOTED
Release for manufacture
Revise and resubmit for distribution
- ☐ RETURNED FOR CORRECTION
Do not proceed
Revise and resubmit for authorization

TOTAL OF (2) HRSG'S REQUIRED

REV	DATE	REVISION	BY	CHK
C	11/15/02	REVISED DIMENSIONS	JA	KA
B	9/24/02	ADDED SAFETY SHROUD	JA	KA
A	6/18/02	INITIAL RELEASE	JA	KA
REV	DATE	REVISION	BY	CHK
A		REVIEWED AND ACCEPTED		
B		REVIEWED WITH COMMENTS (WORK MAY PROCEED)		
C		REVISE AND RESUBMIT (WORK MAY NOT PROCEED)		
D		REVIEWED FOR INFORMATION ONLY		
RELEASE DATE:	11-23-02	REVIEWERS INITIALS:	K RF	

DWN: JA (40)		INLET DUCT ROOF LINER LAYOUT	
CHK: KA		PE: GBW	OWNER: JACKSONVILLE ELECTRIC AUTHORITY (JEA)
PM: MWK		SE: KHM	PURCHASER: BEAK / UTILITY ENGINEERING
TE: BCS			PROJECT: BRANDY BRANCH
			PLANT SITE: BALDWIN, FL
PROJECT: JEA BRANDY		JOB NO. CODE SHT	REV FE
DRAWING NUMBER		014152-FS-023	C

NOTE: ALL INSUL IS LISTED ON 014152-FS-003

* BATTEN CHANNELS, CHANNEL WASHERS & LINER WASHERS ARE SHOP ATTACHED TO WALL, FLOOR & ROOF PANELS WITH REMOVABLE PUSH NUTS. FIELD WILL REMOVE PUSH NUTS, LINER WASHERS, BATTEN CHANNELS & CHANNEL WASHERS PRIOR TO INSTALLING FIELD SEAM LINERS. FIELD SEAM LINERS AND INSULATION FURNISHED BY FIELD SEAM SUPPLIER. FINAL ASSEMBLY PER FIELD ERECTION DETAILS.

