



Procurement Department Bid Office
225 N. Pearl Street
Jacksonville, FL 32202

April 02, 2026

ADDENDUM NUMBER: One (1)
TITLE: Construction Services for Ponte Vedra Wastewater Treatment Facility
SOLICITATION NUMBER: 1412137046
PROPOSAL DUE DATE: ~~April 28, 2026~~ May 12, 2026
TIME OF RECEIPT: 12:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS

JEA is extending the Bid Due Date:

- Original Bid Due Date: April 28, 2026
- New Bid Due Date: May 12, 2026

JEA is adding the following documents as it relates to this Solicitation:

- Original file name: *1412137046 Appendix B – Bid Workbook*
- New file name: *1412137046 Addendum 1 Appendix B – Bid Workbook*
 - Please use the most current version of the Bid Workbook when submitting your response.

JEA is responding to the following questions as shown below:

1. Question:

In Section 11280 - Slide Gates, the material of construction in 2.02 calls for Stainless Steel or FRP with a stainless frame. These are two very different technologies. Which material of construction does JEA want the gates to be manufactured?

Answer:

The gates can be of either material as long as JEA Standard Specifications and project specific requirements are met. The bidding contractor may select the material.

2. Question:

We respectfully request a two-week extension to the bid due date to allow sufficient time to prepare a complete and competitive proposal. Additionally, please let us know if an engineer's estimate is available for this project.

Answer:

Two (2) weeks extension is acceptable. Engineer's opinion of probable construction cost is approx. \$26,500,000.00.

JEA is making the following changes/clarifications to the Technical Specifications:

1. **Section 01014, Part 1.07 E(1)** must read as follows: "The SBR No. 3 and Post-Equalization tanks will be constructed by Contractor". The words "By Others" eliminated.
2. **Section 09900, Part 1.07 A** must read as follows: "The shop coats to be applied shall be suitable for the field coats to be applied under this Contract". The words "By Others" eliminated.

3. **Section 11262, Part 2.11 A(4)** must read as follows: “Weir to be installed by Contractor”. The words “By Others” eliminated.
4. **Section 11262, Part 2.16 D(1)** must read as follows: “A dose-pacing system will be supplied to modulate the lamp UV output in relationship to a signal from an effluent flow meter (supplied and installed by Contractor) and UV intensity sensors”. The words “By Others” eliminated.
5. **Section 11330, Part 2.06 J(6)** must read as follows: “Short-circuit protection requires that a properly-sized circuit breaker or fuses be installed by Contractor”. The words” By Others” eliminated.
6. **Section 11406, Part 2.05 F** must read as follows: “The vent valve box shall be mounted above the decanter by the installing contractor on handrailing provided by Contractor”. The words “By Others” eliminated.
7. **Section 16231, Part 3.03 A(11)** must read as follows: “After installation is completed and normal power is available, the Contractor must perform a one (1) day start-up including the use of building load”. The words “By Others and Vendor” eliminated.

JEA is making the following changes/clarifications to the Bid Workbook:

1. Item 28 added (Disinfection and Bacteriological Tests).
2. Quantities on Items 36 through 40 changed.
3. Item 41 added (Remove and Dispose Material (Sludge/Mud/Organic) Inside the SBR 1, 2 and Tanks).
4. Item 44 description changed.
5. Item 45 added (SBRs - Axial Flow Pumps).
6. Item 46 added (Demolition of Existing Filter No.1, Filter No. 2 & Existing UV Channel).