



Building Community®

Procurement Department Bid Section
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

December 4, 2020

ADDENDUM NUMBER: TWO (2)

TITLE: RFQ 100375 NGS NO.2 Fuel Oil Diesel Line Cleaning for JEA

QUOTE DUE DATE: December 16, 2020

TIME OF RECEIPT: 12:00 PM EST

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR
CLARIFICATIONS:**

- 1. Question:** In reference to the 5400 feet of 12" Diameter piping to be cleaned. Are there Pig launch and Pig retrieval devices for that line?

Answer: We do not have pig launch or retrieval devices but there are launch/retrieval access points, although very limited.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.