



Procurement Department Bid Section
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

July 16, 2021

ADDENDUM NUMBER: ONE (1)

TITLE: 101345 (RFP) NS-3 High Energy Piping (HEP) Non-Destructive Examination (NDE) Project

QUOTE DUE DATE: July 23, 2021

TIME OF RECEIPT: 11:59 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Question:** Do you have a scheduled start and stop date in the 45 day outage for NDE services?

Response: The NDE Service start date will be Monday, Nov 8th 2021, and End Date will be Thursday December 9th 2021.

2. **Question:** Do you have construction scheduled shifts or just a single day shift and is that schedule seven ten hour days or something else?

Response: We're planning on working 10 hour shifts Monday-Friday.

3. **Question:** Are we responsible to provide JEA metallurgical analysis from the surface replications we perform?

Response: The NDE Contractor will need to provide metallurgical analysis of the surface replications.

4. **Question:** Is the visual inspection being performed by JEA or do we need to include that in our inspection?

Response: The NDE Contractor is to include Visual Inspection.

5. **Question:** We understand the code requirements for the scope to include ASME and AWS, can you provide the applicable code and year edition so we can include that in our response and also make sure we provide the applicable procedures for your review.

Response: The most recent Edition of the ASME B31.1 code and most recent addition of the AWS Code shall be used.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.