



Procurement Department Bid Section  
Customer Center 1<sup>st</sup> Floor, Room 002  
21 W. Church Street  
Jacksonville, Florida 32202

July 20, 2021

ADDENDUM NUMBER: TWO (2)

TITLE: 101345 (RFP) NS-3 High Energy Piping (HEP) Non-Destructive Examination (NDE) Project

QUOTE DUE DATE: July 23, 2021

TIME OF RECEIPT: 11:59 PM EST

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

1. **Question:** The specification calls out 2 MS welds, 2 HRH welds and 2 CRH welds that are inside the enclosure, as shown on the NDE Plots in Attachment 5. Can you please clarify whether these 6 welds are, or are not, included in the scope?

The welds in question are:

- Item #3 & #4 on the MS NDE Plot.
- Items #3 & #4 on the HRH NDE Plot (which I believe are duplicates of welds labeled R34 & R45 of Section 4.3 of Appendix A Technical Spec's.)
- Items #5 & #6 on the CRH NDE Plot.

**Response:**

- Item #3 & #4 on the MS NDE Plot **DO NOT** require re-inspection because they were inspected in Dec 2020 and no problems were found.
- Items #3 & #4 on the HRH NDE Plot **DO** require NDE inspection
- Items #5 & #6 on the CRH NDE Plot **DO** require NDE inspection

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.**