



Building Community®

Procurement Department Bid Section
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

June 6, 2022

ADDENDUM NUMBER: TWO (2)

TITLE: 1410742646 (RFQ) Construction Services for Beeghly Heights 8C1 Cap Bank

QUOTE DUE DATE: June 10, 2022

TIME OF RECEIPT: 11:59 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

- 1. Question:** For the installation of a raceway, trenching will need to be done. I am not finding anything in the specifications that state whether or not an excavator is allowed. Will the contractor be required to hand dig the trenches?

Answer: The Contractor will be required to hand dig the trenches.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.