



Building Community®

Procurement Department Bid Section  
Customer Center 1<sup>st</sup> Floor, Room 002  
21 W. Church Street  
Jacksonville, Florida 32202

June 6, 2022

ADDENDUM NUMBER: TWO (2)

TITLE: 1410742846 (RFQ) Construction Services for Craven Road 8C1 Cap Bank

QUOTE DUE DATE: June 10, 2022

TIME OF RECEIPT: 11:59 PM EST

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

- 1. Question:** For the installation of a raceway, trenching will need to be done. I am not finding anything in the specifications that state whether or not an excavator is allowed. Will the contractor be required to hand dig the trenches?

**Answer:** The Contractor will be required to hand dig the trenches.

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.**