



Procurement Department Bid Section

March 25, 2025

ADDENDUM NUMBER: Three (3)

TITLE: 1411937846 (IFB) Fiber Optic Ground Wire (OPGW) for Fulton Cut Replacement

PROPOSAL DUE DATE: March 27, 2025

TIME OF RECEIPT: 12:00 PM EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Question:** Section 7.2.2 cites requirements listed under IEEE-1138 Section 4.1.10, but I am not seeing a Section 4.1.10 in IEEE-1138-2021 (the latest version) and Section 4.1 is simply an overview paragraph. Can you please verify the clause and requirements being referenced?

7.2.2 Fiber Strain Margin: The successful bidder shall provide test data showing that the cable (or one of similar design) meets the requirements of section 4.1.10 of IEEE std 1138, IEEE Standard Construction of Composite Fiber Optic Overhead Ground Wire for Use on Electric Utility Power Lines.

Answer: JEA amends Section 7.2.2 of the Technical Specification as follows:

7.2.2 Fiber Strain Margin: The successful bidder shall provide test data showing that the cable (or one of a similar design) meets the requirements of section 6.4.1.3 of IEEE std 1138-2021

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.