



Procurement Department Bid Office  
225 N. Pearl St.  
Jacksonville, Florida 32202

April 10, 2025

ADDENDUM NUMBER: One (1)

TITLE: 1411959046 (IFB) Electric Generation Plant(s) Fire Protection Repair/Service Contract

RESPONSE DUE DATE: April 17, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

1. JEA adds "1411959046 Addendum 1."
2. **QUESTION:** Would you be able to tell us if it is planet safe foam or not?

**ANSWER:** Yes, we can answer that. No, it isn't planet safe foam. We use AFFF 3%.