



Procurement Department Bid Office
225 N. Pearl St.
Jacksonville, Florida 32202

June 4, 2025

ADDENDUM NUMBER: Two (2)

TITLE: NGS - N03 Station Service Battery Replacement

JEA SOLICITATION NUMBER: 1411984853

RESPONSE DUE DATE: June 11, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. JEA adds "1411984853 Addendum 2"
2. **Question:** Can we work on weekends or is this project just going to be Monday to Friday?

Answer: Yes, weekend work is allowed if necessary.

3. **Question:** Can I also get the exact dates of the facility planned outage?

Answer: Outage is currently planned from 10/16/2025-11/5/2025. Because there needs to be time allotted for charging the new batteries, we are expecting the installation to happen towards the beginning of the outage.