



Procurement Department Bid Office
225 N. Pearl St.
Jacksonville, Florida 32202

July 2, 2025

ADDENDUM NUMBER: One (1)

TITLE: 1412003246 (IFB) Spun Concrete Transmission Poles for the Circuit 416 Nichol's Creek Crossing

RESPONSE DUE DATE: July 15, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. JEA adds "1412003246 Addendum 1"
2. Clarifications:
 - Pole delivery dates can be found in the project specific tech specs on sheet 5. The dates are between August 25 and September 1, 2025.
 - Updated STR 2 PLS .bak and .lca files.
 - Threaded inserts listed as 3/4" should be changed to 1" threaded inserts. All deadend attachments will utilize the same deadend tees.
 - All callouts in the drilling detail that specify "jumper post" insulators should be updated to use 7/8" threaded inserts, not 1".