



Procurement Department Bid Office
225 N. Pearl St.
Jacksonville, Florida 32202

July 2, 2025

ADDENDUM NUMBER: One (1)

TITLE: 1412006646 (IFB) Spun Concrete Transmission Poles for the Circuit 416 Sister's Creek Crossing

RESPONSE DUE DATE: July 15, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 2:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. JEA adds "1412006646 Addendum 1"
2. Clarifications:
 - Pole delivery dates can be found in the project specific tech specs on sheet 5. The dates are between August 25 and September 1, 2025.
 - To clarify from the pre-bid meeting, two poles will be 24kip and two will be 44kip. Please see sheet 6 of the project specific tech specs bid sheet and sheets 8-11 for the pole drawings structure table for all pole basic length and strength information.
 - All callouts in the drilling detail that specify "jumper post" insulators should be updated to use 7/8" threaded inserts, not 1".