



Procurement Department Bid Section  
225 North Pearl Street  
Jacksonville, Florida 32202

December 16, 2025

ADDENDUM NUMBER: Three (3)

---

TITLE IFB Emerson Street Warehouse Pallet Rack Installation / 1412070647

---

RESPONSE DUE DATE: December 19, 2025

---

TIME OF RECEIPT: 12:00 PM EST

---

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

- 1. Question:** What are the sizes/weight of the long wooden crates to be stored on the cantilever rack?

**Answer:** Below are the size of the wooden crates and the heaviest weighs 2,350 pounds.

**INSLP013...12'LONG X 30"H X 42"D & 12'LONG X 45"H X 42"D**

**INSLP014...12'LONG X 45"H X 42"D**

**INSLP015...20'LONG X 30"H X 42"D**

**INSLP020...18'LONG X 30"H X 42"D**

**INSHP025...11'LONG X 36"H X 45"D**

**INSDE002...12'LONG X 30"H X 42"D**

**INSHP034...12'LONG X 30"H X 42"D**

- 2. Question:** What is the weight per level for the selective racking?

**Answer:** Each level should be able to hold to 5,000 pounds.

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE RESPONSE FORM**