



December 1, 2025

ADDENDUM NUMBER: One (1)

TITLE: 1531 Ryar Road Biotrickling Filter & Carbon Polisher

JEA IFB NUMBER: 1412073046

PROPOSAL DUE DATE: ~~December 5, 2025~~ December 12, 2025

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 02:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

JEA is extending the bid due date to December 12, 2025

JEA is responding to the following questions as shown below:

1. Question:

Page one of the technical specifications lists Equipment Delivery in less than 12 weeks from submittal approval. This is extremely short period of time for a custom designed and fabricated piece of process equipment. Please confirm that a delivery of 16 – 24 weeks is acceptable.

Answer:

Delivery of equipment on or before 24 weeks after the Purchase Order is issued acceptable.

2. Question:

Can you confirm that the interconnecting ductwork material of construction should match that of the biotrickling filter and carbon filter vessels?

Answer:

The interconnecting ductwork materials does not need to match.