



Procurement Department Bid Section

July 7, 2026

ADDENDUM NUMBER: ONE (1)

TITLE: 1412186878 (IFB) JEA Overhead Crane and Hoist Inspection and Maintenance

PROPOSAL DUE DATE: ~~July 8, 2026~~ July 15, 2026

TIME OF RECEIPT: 12:00 PM EST

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

1. **Change:** The proposal due date has been extended to July 15, 2026
2. **Question:** For the load test only greater than 15T would a water source be available with appropriate flow to fill water bags? Also, would there be a way to drain the water at the sites?  
**Answer:** Yes, we have the water flow to fill the bags and they can be drained on-site in place.
3. **Question:** Would we be responsible for bringing the manlift equipment for our personnel to use per site?  
**Answer:** Yes, you will need to provide lifts and work platforms as needed to perform work while on site.
4. **Question:** For the frequency I see that is stated as “ annual “ do you require the “ high “ critical assets to be inspected more than once per year? the codes referenced in ( Appendix A ) have varying frequency requirements, I.E monthly frequent inspections as well as the annual periodic inspection.  
**Answer:** We only have inspections completed annually on all assets; however, we do have our turbine floor hoist (250ton) and the 2 A-frame hoists on the turbine floor secondary inspected prior to scheduled outages due to the 24 hour use on them during the outage window. This is not a load tested inspection but more of a general inspection to verify systems are functioning as they should.

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.**