



Building Community®

Procurement Bid Office  
Customer Center 1<sup>st</sup> Floor, Room 002  
21 W. Church Street  
Jacksonville, Florida 32202

January 9, 2019

ADDENDUM NUMBER: **Four (4)**

---

TITLE: **ABESS Lift Station Fiber Build**

JEA ITN NUMBER: **96435**

---

RESPONSE DUE DATE: **January 18, 2019**

---

TIME OF RECEIPT: **12:00 PM**

---

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

**1. CHANGE: NEMA Box size change**

- NEMA Box size is now 24" x 24" x 8".

**2. CHANGE: Delete Item #2 on Scope of Work in Technical Specification Document.**

- From the last handhold on the right-of-way, install approximately 100' of 2" conduit to the pole with the green splice box. Contractor will perform a riser and pull the fiber into the green box.

**Acknowledge receipt of this addendum on the Response Form**