



Building Community®

Procurement Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

January 10, 2019

ADDENDUM NUMBER: **Five (5)**

TITLE: **ABESS Lift Station Fiber Build**

JEA ITN NUMBER: **96435**

RESPONSE DUE DATE: **January 18, 2019**

TIME OF RECEIPT: **12:00 PM**

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. **Question:** In order to enter the electric manholes do we still need a lineman with radio capabilities or JEA approved journeyman?
 - JEA does not have any special requirements; however, they do have to follow these guidelines:
 - **Osha 1910.269 requirements and they will be different depending on conditions of the space 1910.269(a)(2) and 1910.269(e)(2).**

Acknowledge receipt of this addendum on the Response Form