



Procurement Department Bid Office
Customer Center – 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

February 26, 2019

ADDENDUM NUMBER: One (1)

TITLE: Pony Pump Upgrade Remote Terminal Unit (RTU) Back Panel Construction Services

JEA RFQ NUMBER: 96695

PROPOSAL DUE DATE: March 12, 2019

TIME OF RECEIPT: 12:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

1. JEA is responding to the following question as shown below:

Question:

General Note 9 of the provided drawings states that this drawing is for a Pony Pump with a 12VDC starter but indicates that there will be pumps with 24VDC starters as well. Can you tell me what the quantity is for each?

Answer:

All of the pumps will have 12V starters

Acknowledge receipt of this Addendum on the Proposal Form (Appendix B)