



Building Community®

Procurement Department Bid Section  
Customer Center 1<sup>st</sup> Floor, Room 002  
21 W. Church Street  
Jacksonville, Florida 32202

May 9, 2019

ADDENDUM NUMBER: FOUR (4)

---

TITLE: RFQ 97154 Renovation of Cedar Bay District II Buildings 1 & 3

---

BID DUE DATE: May 16, 2019

---

TIME OF RECEIPT: 12:00 PM EST

---

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

- 1. Question: Can JEA identify location, manufacturer, and breaker type for the existing 480V panel?**

**Answer: Contractors will need to verify actual breaker types.**

- 2. Question: Can JEA identify breaker type for Panel 1A?**

**Answer: Contractors will need to verify actual breaker types.**

- 3. Question: Does air handler equipment WSHP-1 & EDH 1 & 2 have their own disconnecting means built into unit or are we to provide alternate disconnecting means?**

**Answer: EDH units 1 & 2 in Building 1 are not required, DELETE from Bid. Reference Appendix C – Drawings – M3.0**

- 4. ADD: Disconnect for WSHP-1 – Appendix C – Drawings – M3.0**

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID FORM.**