



Building Community®

Procurement Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

May 16, 2019

ADDENDUM NUMBER: One (1)

TITLE: 7200 AC Skinner Lift Station Fiber Build

JEA ITN NUMBER: 97294

RESPONSE DUE DATE: May 28, 2019

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 12:00 PM

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:

Question:

1. Print appears to have aerial work, but the pricing sheet does not have units for aerial work. how do we submit prices for aerial work?

Answer:

1. This bid does not include aerial construction, only underground construction.

Question:

2. Is there spec on patch panel that we are to provide?

Answer:

2. Latest Corning ST patch panel spec.

Question:

3. In the scope of work it states we're installing a riser pole, who is providing pole? Is there a spec?

Answer:

3. Should be a 2" riser guard, no poles need to be set. No additional spec needed.

Acknowledge receipt of this addendum on the Response Form