



Building Community®

Procurement Bid Office  
Customer Center 1<sup>st</sup> Floor, Room 002  
21 W. Church Street  
Jacksonville, Florida 32202

July 18, 2019

ADDENDUM NUMBER: Two (2)

TITLE: 128 Hedgerow Master Lift Station Fiber Build 2019

JEA ITN NUMBER: 97743

RESPONSE DUE DATE: July 24, 2019

TIME OF RECEIPT: 12:00 PM

TIME OF OPENING: 12:00 PM

**THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

**Question:**

1. What color should the two and four inch conduit be?

**Answer:**

1. The two and four inch conduit should be gray in color.

**Question:**

2. Should the inner ducts also be gray in color?

**Answer:**

2. Clarification from Addendum 1, no color preference on inner ducts.

**Question:**

3. After the discussions during the pre-bid meeting regarding the “Aerial Cable”, will line #10 on the Response Workbook be removed?

**Answer:**

3. The “Aerial Cable” will remain on the Response Workbook, as the contractor will perform a small amount of aerial work.

**Question:**

4. After the discussions during the pre-bid meeting, will #8, “Risers” be removed from the Response Workbook?

**Answer:**

4. The “Risers” will remain on the Response Workbook.

**Question:**

5. Response Workbook item #4 indicates 168 splices. Does that include the 12 terminations at Hedgerow Lift Station, 12 terminations at Switzerland Substation, and also a 144 fiber reel end butt splice?

**Answer:**

5. Yes, per the Response Workbook.

**Acknowledge receipt of this addendum on the Response Form**