



Procurement Bid Office
Customer Center 1st Floor, Room 002
21 W. Church Street
Jacksonville, Florida 32202

August 20, 2019

ADDENDUM NUMBER: **One (1)**

TITLE: **HAMILTON STREET SUBSTATION BREAKER 307, 308, 310, 311 & 312 REPLACEMENTS**

JEA RFQ NUMBER: **97868**

BID DUE DATE: **August 22, 2019**

TIME OF RECEIPT: **12:00 PM**

TIME OF OPENING: **12:00 PM**

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS in Red below:

1. **Clarifications** see below.
 - Contractor shall provide and install five (5) total double pole, 30 amp circuit breakers (assume all branch circuit breakers will need to be replaced).
 - Note on cable schedule, drawing #HA2019-CT, that type "C" cable (all 240VAC feeds to new breakers) shall be provided and installed by the contractor.
2. **Revised and replaced** - Appendix A – HA2019 – SECTION 5 – Drawings - Addendum #1.
3. **Question #1:** Can JEA provide a drawing showing the electrical plan and a typical section?

Answer #1: Yes, please refer to the attached Addendum 1 Appendix A HA2019 - SECTION 5 drawing set which includes new drawings HA2019-EP and HA2019-E5 (drawings #3 and #4) as requested. Please note: This drawing set shall replace the initial drawing set in its entirety.

****Acknowledge receipt of this Addendum on the submitted Bid Form****

